

## TEST REPORT

**REPORT NO.:** 2012FE0405

**PAGE:** 1 OF 19

This Test Report refers only to samples submitted by the applicant to SIRIM QAS International Sdn. Bhd. and tested by SIRIM QAS International Sdn. Bhd. This test report shall not be reproduced, except in full and shall not be used for advertising purposes by any means or forms without written approval from Managing Director, SIRIM QAS International Sdn. Bhd. Please refer overleaf for Conditions Relating to The Use of Test Report.

**Applicant/  
Manufacturer** : GAYADOR SDN. BHD.  
 Lot 11133, Jalan Meranti 5,  
 Batu 18, Pulau Meranti,  
 47120 Puchong,  
 Selangor Darul Ehsan.  
 (Attn.: Mr. Henry Wong )

**Product** : Electronic Card Lock

**Reference  
Standard/  
Method of Test** : Fire resistance test utilising the test methodology given in  
 MS 1073: Part 2: 1996  
 Specification for Fire Resistant Doorsets  
 Part 2: Methods for determination of the fire resistance  
 - General Principles

**Description of test  
specimen** : Electronic Card Lock      Brand : BE TECH      Model : 2063-G1A8M-65A  
 PP2 ref. : PG020415      Date : 02.03.2012  
 Requested by : En. Irfan Abdullah Khalit  
 ICCS (Fire Group),  
 SIRIM QAS International Sdn. Bhd.  
 Doorset      Brand : GAYADOR      Model : GD FR S/L (M) 60-C IV  
 Door leaf : 1100 mm (h) × 1003 mm (w) × 43.8 mm thick (t)  
 overall dimension  
 Rating : 1 Hour

The doorset was verified by the Fire Protection Section's Testing Executive on the dimensions and design. Full description of the test construction of the doorset is detailed in Page 3 and 4 of this report.

**Test results** : Based on the test conducted, the Electronic Card Lock satisfied the requirements of the MS 1073: Part 3: 1996 for the period stated below :


**Integrity : 65 minutes**

**Date of test** : 29.10.2012


**Date received** : 20.03.2012

**Job No./ Ref No.** : J20121280098/SQAS/FPS/15/1-3

**Issued date** : 28 NOV 2012

  
 -----  
**ABDULLAH SYAHRIL MAT JANI**  
 Testing Executive



  
 -----  
**ZAINI AHMAD**  
 Group Leader  
 Fire Protection Section  
 Testing Services Department  
 SIRIM QAS International Sdn. Bhd.